



Town of Charlotte

ESTABLISHED 1762

WASTEWATER SYSTEM AND POTABLE WATER SUPPLY PERMIT

LAWS/REGULATIONS INVOLVED

Environmental Protection Rules

Chapter 1, Wastewater System and Potable Water Supply Rules,
Effective September 29, 2007

Chapter 21, Water Supply Rules, Effective April 25, 2005

Case Number: WW-138-0809

PIN: EJ08-0224

Landowner: Steven Davis
P. O. Box 445
Hartford, VT 05407

This permit affects property identified as Town Tax Parcel ID# 00003-2572 and referenced in deeds recorded in Book 156, Page 605 of the Land Records in Charlotte, Vermont.

This project, consisting of a best fix replacement system for an existing 3 bedroom single family dwelling and a best fix replacement filtrate mound system for a new 4 unit condominium with 2 bedrooms in each unit on the subject property, a 3.15 acre parcel located on Hinesburg Road in Charlotte, Vermont, is hereby approved under the requirements of the regulations named above, subject to the following conditions.

GENERAL

1. This permit does not relieve the permittee from obtaining all other approvals and permits as may be required from the Act 250 District Environmental Commission, the Department of Environmental Conservation, Water Supply Division-telephone (802)241-3400, Water Quality Division-telephone (802)241-3770, the Department Public Safety, Division of Fire Safety-telephone Williston Regional Office (802)879-2300, the Department of Health-telephone (802)863-7221, and local officials prior to proceeding with this project.
2. The project shall be completed as shown on the following plans which have been stamped "approved" by the Wastewater Management Division:

Dwg. 1 of 9, "Existing Conditions Plan" dated July 05, 2007; Dwg. 2 of 9, "Best Fix Wastewater Disposal & Water Supply Plan" dated July 05, 2007; Dwg. 3 of 9, "Best Fix Wastewater Disposal & Water Supply Plan 2" dated July 05, 2007; Dwg. 4 of 9, "Best Fix Wastewater Disposal & Water Supply Plan 3" dated July 05, 2007; Dwg. 5 of 9, "Best Fix Wastewater Disposal Plan" dated May 01, 2008; Dwg. 6 of 9, "Best Fix Wastewater Disposal Details" dated July 05, 2007; Dwg. 7 of 9, "Best Fix Wastewater

159 FERRY ROAD P.O. BOX 119 CHARLOTTE, VERMONT 05445-0119

TOWN CLERK: (802) 425-3071 ♦ PLANNING & ZONING: (802) 425-3533 ♦ LISTER: (802) 425-3855 ♦ FAX: (802) 425-4241

Disposal Details 2” dated July 05, 2007; Dwg. 8 of 9, “Best Fix Wastewater Disposal Details 3” dated July 05, 2007; and, Dwg. 9 of 9, “Water System Details” dated October 17, 2007 prepared by Christopher D. Holzwarth, Licensed Designer #410 and Charles J. Bacon, P. E. No. 235.

The project shall not deviate from the approved plans in a manner that would change or affect the exterior water supply or wastewater disposal system, building location or the approved use of the building without prior written approval from the Wastewater Management Division.

3. The conditions of this permit shall run with the land and will be binding upon and enforceable against the permittee and all assigns and successors in interest. The permittee shall be responsible for the recording of this permit in the Charlotte Land Records within thirty, (30) days of issuance of this permit and prior to the conveyance of any lot subject to the jurisdiction of this permit.
4. Each prospective purchaser of the lot/unit shall be shown copies of the Wastewater System and Potable Water Supply Permit and the approved plans prior to conveyance of the lot.
5. This project has been reviewed and approved for the existing/construction of one multi-unit structure consisting of 4, 2 bedroom single family dwellings on the subject lot. The permittee shall not construct any type of structure requiring plumbing, including public buildings, duplexes, condominium units, or commercial buildings, without prior review and approval by the Wastewater Management Division. Such approvals will not be granted unless the proposal conforms to the applicable laws and regulations.
6. All conditions set forth in Permit #WW-138-0809 shall remain in effect except as modified or amended herein.
7. The Wastewater Management Division now reviews the water supply and wastewater disposal systems for all buildings under 10 V.S.A., Chapter 64-Potable Water Supply and Wastewater System Permit.
8. This permit shall in no way relieve you of the obligations of Title 10, Chapter 48, Subchapter 4, for the protection of groundwater.
9. A copy of the approved plans and this permit shall remain on the project during all phases of construction and, upon request, shall be made available for inspection by State or local personnel.
10. Any lot depicted on the plans and not specifically referenced as being approved for a use requiring a potable water supply and wastewater disposal system shall comply with the

Environmental Protection Rules, Chapter 1, Wastewater System and Potable Water Supply Rules, Effective January 1, 2005, Section 1-403 (a)(5) for the creation of unimproved lots.

WATER SUPPLY & WASTEWATER DISPOSAL

11. No permit issued by the Secretary shall be valid for a substantially completed potable water supply and wastewater system until the Secretary receives a certification from a designer or the installer, signed and dated, that states:

“I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and the potable water supply and wastewater system were installed in accordance with the permitted design and all permit conditions, were inspected, were properly tested, and have successfully met those performance tests.”

This shall include the water supply and wastewater disposal systems, and, water service and sanitary sewer lines to each structure.

12. The project is approved for an on-site water supply system from drilled wells provided that the wells are located as shown on the approved plan. The Wastewater Management Division shall allow no other method, or location of obtaining potable water without prior review and approval.
13. The well locations shall meet all minimum separation distances required by the Environmental Protection Rules, Chapter 21, Water Supply Rule, Appendix A, Part 11- Small Scale Water Systems, Section 11.4. The well(s) shall be constructed in accordance with the Appendix A, Part 12.
14. The project is approved for wastewater disposal by construction and utilization of the site-specific wastewater disposal systems depicted on the approved plans. The Wastewater Management Division shall allow no other method, or location of wastewater disposal without prior review and approval.
15. Unit 2 and Units 3-6 are approved for mound wastewater disposal systems provided the mounds are constructed in strict accordance with the following conditions:
 - A. The mound system is to be located and constructed as depicted on the plans that have been stamped “approved” by the Wastewater Management Division.
 - B. A licensed designer, who has been determined acceptable by the Wastewater Management Division, shall inspect the mound system during critical stages of construction. This shall include the staking of the location of the mound, ensuring the

site has been properly plowed prior to placement of the appropriate sand fill, the installation and testing of the distribution piping, final grading of the mound including side slopes, and pump station installation

- C. The construction of the mound shall adhere to the guidelines set forth in Section 1-517 (f) of the Wastewater System and Potable Water Supply Rules.
 - D. The qualified consultant shall inspect the construction of the curtain drain if required.
 - E. Upon completion of construction, and prior to occupancy of any structure being served by the mound system, the licensed designer, who has been determined acceptable by the Wastewater Management Division, shall submit a written certification stating the construction has been completed in accordance with the stamped plans and the permit.
16. The approved wastewater disposal systems have been designed to serve an existing, 3 bedroom single-family residence and a proposed, 4 unit condominium, each unit having 2 bedrooms. Prior to any increase in bedrooms, the landowner shall submit an application, fee, and engineering plans for review and approval by the Wastewater Management Division.
 17. The Wastewater Management Division is to be notified, if at any time the wastewater disposal system fails to function properly and/or creates a health hazard.
 18. No buildings, roads, water lines, or other construction that might interfere with the installation or operation of the wastewater disposal system is allowed on or near the site-specific wastewater disposal system or replacement area depicted on the approved plans. All isolation distances, which are set forth in the Wastewater System and Potable Water Supply Rules, will be incorporated into the construction and installation of the wastewater disposal field. Compliance with these isolation distances is required
 19. Unit 1 is authorized to utilize the existing on-site wastewater disposal system provided it is operated at all times in a manner that will not discharge wastewater/effluent onto the ground surface or into the waters of the State. If at any time this system fails to function properly and/or creates a health hazard, the Division is to be immediately notified.

20. The use of the performance-based wastewater disposal system approved in this permit requires that an annual inspection be performed by a class 1 or class B designer starting when the system is placed in use. The field inspection shall be done in April or May of each year and a written report shall be submitted to the permittee and the regional office that issued the permit by the following June 15th. The inspection shall consist of a field inspection of the area where the leachfield has been installed. A visual observation of the surface area over the system and the area within 25' of the system in all directions shall be made for any indication of failure. This inspection requirement does not require the installation or observation of groundwater monitors and does not require inspection of other component of the wastewater system such as septic tanks, pump stations or advanced treatment systems. Such inspections may be required if they are part of the approved design, including any operation manuals or written instructions, or if they are required in another permit condition. This condition remains in effect until three inspection cycles have been completed as specified in this condition.

Dated at Charlotte, Vermont on June 18, 2008

Justin G. Johnson, Acting Commissioner
Department of Environmental Conservation

By 
Thomas Mansfield
Sewage Control Officer
Town of Charlotte, Vermont

Cc: For the Record
Town of Charlotte
Steven Davis
Christopher D. Holzwarth