

**Jason Barnard**  
**Consulting, LLC**  
4400 VT Route 17  
Starksboro, VT 05487  
(802) 453-2597 Phone  
(802) 453-8497 Fax

September 8, 2015

Town of Charlotte  
Planning and Zoning Department  
Attn: Jeannine McCrumb  
159 Ferry Road  
Charlotte, Vermont 05445

Subject: Nancy J. Faulkner, 30.7+/- Acre Parcel, 283 Higbee Road, Charlotte, VT - Wastewater System and Potable Water Supply Permit Application


Dear Jeannine:

Enclosed you will find two (2) copies (full size and 11"x17") of Drawings No. 1 and No. 3 for the Nancy J. Faulkner, 30.7+/- Acre Parcel, 283 Higbee Road, Charlotte, Vermont. As per the recommendations in Brian Tremback's recent e-mail correspondence, the following revisions were made to design Drawings No. 1 and No. 3:

1. The pump station dose volume was revised on to provide 105 gallons per dose. In addition, the mound system basis of design was revised to reflect this change.
2. Minimum operating requirements of the pump were included on Drawing No. 3.
3. Note #9 on Drawing No. 1 was expanded to specify a plastic riser and water-tight cover over the effluent filter access associated with the septic tank to allow for routine cleaning of the effluent filter.
4. As stated in Note #7B on Drawing No. 1, a request for a variance has been made relative to maintaining separation to the top of a bank with a slope that is greater than 30%. By way of this letter, a formal request for this variance is made in accordance with Subsection 1-806 of the current Environmental Protection Rules.
5. As per our discussions on September 8<sup>th</sup>, since the two Wastewater System and Potable Water Supply Permit Applications are the same, there is no need to fill out the new application form for this project.

It is important to note that no changes or alterations were made to Drawing No. 2. I believe the attached information addresses the comments outlined in your recent e-mail. Should you have any further questions or comments and/or require additional information relative to this project, please do not hesitate to give me a call at (802) 453-2597.

Sincerely,



Jason S. Barnard  
Licensed Designer #430-B

c: James and Nancy Faulkner