



TO THE BOARD OF SELECTMEN OF THE TOWN OF CHARLOTTE, VERMONT

Comes the Green Mountain Power Corporation, your petitioner, and respectfully represents that in order to furnish adequate service to its patrons it is necessary to replace and reconductor primary power lines along and adjacent Lake Road & Whalley Road. In most situations the poles will be replaced, but due to the nature of the new conductor to be installed (1/0 poly coated tree wire) there will be locations that will require additional poles to shorten the span distances. The poles will be 45' poles with 7' of the poles will be in the ground, with only 38' out of the ground. Trimming should be minor as most of this line is adjacent to open land. One area of concern is Lake Road between 2843-2969, the alley arm construction that we are currently using will not work with the heavier conductor. We will either need to remove the large tree that we currently skirt around or relocate the line on the east side of the road causing the need to remove many more trees on that side (area of provided print circled in red).

The Company further represents that such work will be done in accordance with the plans and specifications attached, and in a manner safe for public travel and subject to the rules thereof. Also, that it is not desirable to make such locations otherwise than shown on the attached plan.

WHEREFORE, your petitioner requests permission from the Board of Selectmen to locate poles guys and wires as aforesaid.

Dated at Colchester, Vermont, this 29th of January 2016.

GREEN MOUNTAIN POWER CORPORATION

By: Joe Bobee
Joe Bobee
Distribution Designer

APPROVED:

Board of Selectmen

Of the

Town of Charlotte

DATE: _____