



VERMONT CONTOURS Inc.

P.O. BOX 384, BRISTOL, VT 05443

6/3/15

Jeannine McCrumb, Planner & Zoning Adm.
Town of Charlotte
Po Box 119
Charlotte, Vermont
05445

Re: Williamson Disposal system upgrade, 6 Wishbone Lane, Charlotte, Vermont

Dear Jeannine,

I have enclosed the replacement septic design along with the state wastewater application for the above mentioned property off Cedar Beach Road. This proposal includes a replacement mound for an existing 3-bedroom residence to upgrade a failing mound disposal area. I have discussed the proposal with the Town's consultant, Brian Tremback, and previously emailed a draft of the proposal for his review. The upper portion of the existing mound system, constructed in the '80's, will be removed and replaced with mound sand sized to meet current requirements. There is an existing curtain drain that will remain in place to dewater the area where the proposed replacement system is to be located. The existing drilled well will remain unchanged and is greater than 100' from the proposed replacement. Given the size of the parcel and options available for a replacement system it is my opinion this proposal is a reasonable upgrade solution for the existing residence. If you have questions regarding the proposal feel free to contact me. Thank You.

Sincerely,

Spencer K. Harris, for
Vermont Contours, Inc.