



208 Flynn Avenue, Suite 2A, Burlington, VT 05401 • tel. 802.863.6225 • fax 802.863.6306

December 15, 2011

Thomas Mansfield
Sewage Control Officer
Town of Charlotte
159 Ferry Road
PO Box 119
Charlotte, VT 05445-0119

Re: Hengelsberg/Samter—988 Prindle Rd, Charlotte, Permit WW-138-0915 Installation Certification

Dear Thomas,

The sewer disposal system for the above referenced project was reviewed by Engineering Ventures throughout construction and was installed in general conformance with the stamped plans and the permit.

I visited the site on October 17, 2009 to witness the layout and staking of the mound system and the initial plowing of the site prior to placement of the appropriate fill. I also visited the site on October 24, 2009 to witness the pump station test and corresponding orifice pressure and flow distribution test, both of which passed

The enclosed C1.0 Record plan includes the as-built condition for 3 minor items:

- 1) The new septic tank that was installed in a slightly different location than the old tank,
- 2) The correct locations for the curtain drains and,
- 3) The willow tree was deleted from plan since this was cut down as part of the mound installation.

Thank you for your assistance with this project. Please call (863-6225) if you have any questions or need additional information.

Sincerely,

A handwritten signature in black ink, appearing to read 'Kevin Worden', written over a horizontal line.

Kevin Worden
Vice President

Cc: Tom Hengelsberg and Linda Samter

Enclosed: C1.0 Record drawing