



TRAFTON
ENGINEERING
ASSOCIATES, LLC

December 8, 2014

Ms. Jeannine McCrumb, Administrative Officer
Town of Charlotte
159 Ferry Road
P.O. Box 119
Charlotte, VT 05445

Re: Wastewater System Construction Certification WW-138-1127
Colin Rehkgler, 939 Dorset St., Charlotte, VT 05445

Dear Ms. McCrumb:

This letter is to provide Construction Certification for the above referenced property in accordance with permit approval WW-138-1127.

Trafton Crandall P. E. of Trafton Engineering Associates LLC provided on-site field inspection during critical times of the construction process. The potable water supply and wastewater system were installed in accordance with the approved plans and in accordance with the State of Vermont wastewater standards.

This installation includes an "Innovative/Alternative System" (IAS). The approved system was the EcoFlow Biofilter Model STB-650BR. This system is no longer available locally. The system installed was the Jet J750, as supplied through Onsite Septic Solutions, LLC. This is a State approved IAS # 2013-02, which is an equivalent substitution. The Owner has a maintenance contract in place with Bundy Septic Services. The approval letter #2013-02 has been provided to the Owner.

RECEIVED
DEC 12 2014
CHARLOTTE
PLANNING & ZONING

343 ORCHARD ROAD CHARLOTTE, VT 05445
P. 802.425.7761 C. 802.497.7258 TRAFTONMC@GMAVT.NET

CERTIFICATION

I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and that the potable water supply and wastewater system were installed in accordance with the permitted design and all permit conditions; were inspected; were properly tested; and have successfully met those performance tests.

Trafton M. Crandall, P. E. License # 8136


Signature

Dec. 08, 2014
Date

Please call me with any questions regarding this matter.

Sincerely,

TRAFTON ENGINEERING ASSOCIATES LLC

Trafton M. Crandall, P. E.

Cc: Colin Rehkugler