

HIGH KNOB DESIGN ASSOCIATES LLC

981 Big Hollow Road

Starksboro, Vermont 05487 • (802) 385-1073

June 11, 2018

Aaron Brown
Charlotte Zoning Administrator
159 Ferry Road
PO Box 119
Charlotte, Vermont 05445

Re: 3119 Guineau Road, WW-138-1406R

Dear Mr. Brown

I am writing to report the completion of the construction of the water/wastewater systems for Charles & Missy Adams 3119 Guineau Road, Charlotte. The water/wastewater systems were installed in accordance with the approved plans prepared by Jeffrey Keeney dated 3/19/14 last revised 4/18/17 and permit conditions of permit WW-138-1406R.

During the course of construction, I staked out the well and mound locations inspected the septic tank, plowing, placement of Presby pipes and sand fill, final grading and well. There is a small depression around the inlet cover this area should be re-graded to slope away from the cover.

I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and the wastewater system was installed in accordance with the permitted design and all permit conditions, were inspected, were properly tested, and have successfully met those performance tests.

Feel free to call if you have any further questions or concerns regarding this.

Sincerely,



Jeffrey Keeney
Licensed Designer 377-B

Cc: Black Rock Construction