

KREBS & LANSING

Consulting Engineers, Inc.

164 Main Street
Suite 201
Colchester, VT 05446
Telephone (802) 878-0375; Fax 878-9618
email@krebsandlansing.com

November 6, 2018

Aaron Brown
Town of Charlotte
P.O. Box 119
Colchester, VT 05445

**RE: W Terence Breen Family Trust/Breen & Shea Ventures LLC
Red Truck Lane
Permit # WW-4-2182-2**

Dear Aaron,

We made site visits during construction of the wastewater disposal system for the above referenced project. The following aspects of the project are now complete:


- The 1,500 gallon Simplified STEP tank "A" has been installed at the 1 bedroom carriage house.
- The force main has been installed and relocated to connect the carriage house wastewater system to the existing "Lot 2" wastewater disposal system.

Simplified STEP tank "B" and associated piping has not been installed and is not part of this certification.

Based on our observations, the system was constructed in accordance with the approved plans and permits, and all necessary separation distances were maintained.

"I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information submitted is true and correct and potable water supply system and wastewater system were installed in accordance with the permitted design and all permit conditions, was inspected, was properly tested, and has successfully met those performance tests."

Regards,



Scott Homsted, P.E.

cc: Terry Breen