



Vermont Well & Pump
14337 Route 116 100674
Hinesburg, VT 05461
Atten: Rob Frost

PROJECT: Philo Ridge Farm
WORK ORDER: 1706-12392
DATE RECEIVED: June 08, 2017
DATE REPORTED: June 13, 2017
SAMPLER: Paul Bent

VTP

Laboratory Report

Enclosed please find the results of the analyses performed for the samples referenced on the attached chain of custody. All required method quality control elements including instrument calibration were performed in accordance with method requirements and determined to be acceptable unless otherwise noted.

The column labeled Lab/Tech in the accompanying report denotes the laboratory facility where the testing was performed and the technician who conducted the assay. A "W" designates the Williston, VT lab under NELAC certification ELAP 11263; "R" designates the Lebanon, NH facility under certification NH 2037 and "N" the Plattsburgh, NY lab under certification ELAP 11892. "Sub" indicates the testing was performed by a subcontracted laboratory. The accreditation status of the subcontracted lab is referenced in the corresponding NELAC and Qual fields.

The NELAC column also denotes the accreditation status of each laboratory for each reported parameter. "A" indicates the referenced laboratory is NELAC accredited for the parameter reported. "N" indicates the laboratory is not accredited. "U" indicates that NELAC does not offer accreditation for that parameter in that specific matrix. Test results denoted with an "A" meet all National Environmental Laboratory Accreditation Program requirements except where denoted by pertinent data qualifiers. Test results are representative of the samples as they were received at the laboratory

Endyne, Inc. warrants, to the best of its knowledge and belief, the accuracy of the analytical test results contained in this report, but makes no other warranty, expressed or implied, especially no warranties of merchantability or fitness for a particular purpose.

Reviewed by:

Harry B. Locker, Ph.D.
Laboratory Director

Laboratory Report

DATE REPORTED: 06/13/2017

CLIENT: Vermont Well & Pump

WORK ORDER: **1706-12392**

PROJECT: Philo Ridge Farm

DATE RECEIVED 06/08/2017

001	Site: Lawn Hydrant		Date Sampled: 6/8/17		Time: 14:36				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.		
Total Coliform	< 1.0	MPN/100mls	SM20 9223B(97)	6/8/17 17:51	W CM	A	AN1		
e. coli	< 1.0	MPN/100mls	SM20 9223B(04)	6/8/17 17:51	W CM	A			
Nitrate as N	0.21	mg/L	EPA 300.0	6/9/17 3:25	W CM	A			

Report Summary of Qualifiers and Notes

AN1: Please Note our coliform sample bottles have recently changed. EPA requirements for this analysis specify one inch of head space above the water level in the bottle to allow for adequate mixing of the sample prior to analysis. The water level should not be above the shoulder into the neck of the bottle (over the 120 mL line).