From: Andre Lambert
To: Aaron Brown
Subject: RE: Weidman WW Application
Date: Tuesday, July 10, 2018 11:50:47 AM
Attachments: 18-091 C3-01 Sanitary Plan (1).pdf
18-091 C8-01 (1).pdf
18-091 C8-02 (1).pdf
4- WW App Form.pdf

Good morning Aaron,

You are correct in your evaluation of our intent. The Weidman system is over 30 years old and is backed up into the dbox. They have been pumping every 10 days or so. Brian Tremback and I discussed the options and found this was the only place we could put a mound system that would work. The upper pits are largely fill material with the receiving pit being sand to 17", then native material underneath. We are intending to add 26" of mound sand under the system.

Please find the attached documents for your review….

Regards, Andy

From: Aaron Brown [mailto:zoningadmin@townofcharlotte.com]
Sent: Tuesday, July 10, 2018 11:15 AM
To: Andre Lambert
Subject: Weidman WW Application

Hi Andy,

I received the Weidman application. As I understand it, the applicant proposes to replace a failed two-bedroom system with a new two-bedroom system. Correct? Also, please send an electronic version of the application and a brief cover letter when you have a chance.

Best,
Aaron

Aaron Brown
Town of Charlotte
Zoning Administrator/Sewage Control Officer/E-911 Coordinator/Public Health Officer
802-425-3533 x. 207