

GREEN MOUNTAIN ENGINEERING, INC.

1438 South Brownell Road
Williston, VT 05495
(802) 862-5590 (Fax) 862-7598

October 20, 2011

Mr. Thomas Mansfield,
Sewage Control Officer
Town of Charlotte
P.O. Box 119
Charlotte, VT 05445-0119

RE: Connection to Existing Wastewater Disposal and Water Supply System
Carleton Permit #WW-138-0910
GME Project No. 15-039

Dear Mr. Mansfield;

For your information, Wes Patenaude has completed the construction of the connection of a detached, 1-bedroom cottage with bathroom to the existing, onsite water supply and wastewater disposal system. Please note that due to ledge considerations, the system was installed with two (2) minor variations:

1. The septic tank / pump station was installed off the southeast corner of the building, and
2. The connection to the existing disposal area was made from the south side of the existing cabin.

Neither variation impacts the intended design or expected performance of the system. Testing and dose volume verification were performed by the contractor.

Therefore, I hereby certify that, in the exercise of my reasonable professional judgment, the installation-related information is true and correct and the potable water supply and wastewater system were installed in accordance with the permitted design and all permit conditions, were inspected, were properly tested, and have successfully met those performance tests.

If you have any questions or comments regarding this information, feel free to contact me at (802) 862-5590.

Sincerely,
GREEN MOUNTAIN ENGINEERING, INC.


Alan Huizenga, P.E.
President

cc: Mr. & Mrs. Nathaniel Carleton w/ invoice enclosed