



TYPICAL INDIVIDUAL WATER SYSTEM

NOT TO SCALE



TYPICAL TNC DRILLED WELL

NOT TO SCALE



TYPICAL WATER TRENCH

NOT TO SCALE

INDIVIDUAL DRILLED WELL NOTE:

1. THE SUBMERSIBLE PUMP MODEL AND DEPTH OF SETTING TO BE SPECIFIED BY THE ENGINEER AFTER THE WELL IS DRILLED AND YIELD TESTED (PIPE AND ADAPTOR SIZE TO SUIT ALSO).

POTENTIAL SOURCE OF CONTAMINATION AND OTHER SITING LIMITATIONS	SEPARATION DISTANCE
Roadway, Parking Lot (outer edge of shoulder)	25 Feet
Driveway (Fewer than 3 residences)	15 Feet
Sewage System Disposal Fields	(See a.)
Subsurface Wastewater Piping and Related Tanks	50 Feet
Property Line	10 Feet (See b.)
Limit of Herbicide Application on utility R.O.W.	100 Feet (See c.)
Surface Water	10 Feet (See d.)
Buildings	10 Feet
Concentrated Livestock Holding Areas and Manure Storage Systems	200 Feet
Hazardous or Solid Waste Disposal Site	(See f.)
Non-sewage Wastewater Disposal Fields	(See f.)

DRILLED WELL ISOLATION DISTANCES

- a. See Table a11-2.
- b. Increased to 50' when adjacent to agricultural cropland.
- c. Applies to rights-of-way (ROW) where herbicides have been applied in the past 12 months or may be applied in the future. This distance may be increased to 200' depending on the active ingredient in the herbicide according to Vermont Regulations for Control of Pesticides.
- d. For Public water sources, see appendix A, Part 3, Subpart 3.4.
- e. Water sources shall not be located in a flood way.
- f. If a water source is potentially downgradient of a source of contamination, then the Secretary shall apply criteria in Appendix A Subpart 11.4.2.2.

INDIVIDUAL DRILLED WELL DESIGN DATA

1. THE DRILLED WELL(S) CONSTRUCTION, LOCATION, DISINFECTION, AND TESTING SHALL BE IN ACCORDANCE WITH THE STATE OF VERMONT - WATER SUPPLY RULES.

2. THE BASIS OF DESIGN FOR TNC DRILLED WELL IS:

- A. AVERAGE DAY DEMAND: 1,800 GPD
- B. MAXIMUM DAILY DEMAND: 1,800 GPD/720 MIN/DAY = 2.5 GPM
- C. OPERATING PRESSURE RANGE: 40-50 PSI AT PRESSURE SWITCH
- D. INSTANTANEOUS PEAK DEMAND = 22.0 GPM.


NOT TO SCALE



"I hereby certify that in the exercise of my reasonable professional judgment the design-related information submitted with this application is true and correct, and that the design included in this application for a permit complies with the Vermont Wastewater System and Potable Water Supply Rules and the Vermont Water Supply Rules."

Alan Huizenga, P.E.
VT Professional Engineer #5905
GME Project No. 19-019.14

Stephen Revell, CPG
Licensed Designer #178-B



Hunt Property
1297 Ethan Allen Highway
Charlotte, Vermont

Activity Barn
TNC Water System
General Design Details

LAG PROJECT #
14007
DATE:
Nov. 6, 2014
SURVEYORS:
TAM/CZ
DRAWN BY:
TAM
FIGURE #:
1